

# El Toro – Clute Energy Efficiency Trial

Before



After



# Project Implementation

- A KWH data logger was placed on the unit 2 weeks prior to starting the project.
- At the 2 week point, the unit condenser coil and cabinet were cleaned.
- The condenser coil was coated with MicroGuard AD 35 siloxane coating to prevent corrosion and enhance energy efficiency.
- The exterior cabinet was coated with an Energy Star Ceramic coating to protect against corrosion and to provide a radiant barrier against solar heat gain, which reduces load and energy consumption . Exterior cabinet temperature was reduced from 135°F to 92°F.
- KWH data logger continued to collect data for 2 weeks after.

# Data Logging Equipment

(Records KWH energy usage)





# Summary of Project Results

- Corrosion protection for coil and exterior cabinet, extends life of unit and avoids capital cost replacement. Life cycle extension 25 to 50%
- Reduced coil fouling and reduced maintenance time for cleaning coil.
- Reduced peak demand
- Energy consumption (KWH) reduced on a 3 month old unit by 24%
- Simple ROI for a single unit 17 months. Simple ROI for a complete roof top 13 months (20% discount applied).
- IRR – 91.46% or 91.46% interest earned on the investment
- NPV – Net Present value of project \$32,277

# Project Potential

Implementation of the coating project on all of the units on this roof and the other facilities within the customer's portfolio, will have a substantial positive impact on their operating cost and overall bottom line.

Savings will be achieved in:

Energy consumption KWH

Peak demand KW

Reduced maintenance cost

Reduced mean time to failure

Reduced capital cost replacement budget